



*Delivering more than
just test results*

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

August 30, 2016

Bonny Ray
Linn Benton Lincoln ESD
905 4th Avenue SE
Albany, OR 97321
TEL: (541) 812-2712
FAX

RE: Lead Testing

Order No.: 1608431

Dear Bonny Ray:

Analytical Laboratory Group received 29 sample(s) on 8/9/2016 for the analyses presented in the following report.

A handwritten signature in black ink, reading 'Kimberly J. Reeve Morghan'.

Kimberly Reeve Morghan
Quality Manager
361 West 5th Ave
Eugene, OR 97401



*Delivering more than
just test results*

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Case Narrative

WO#: **1608431**

Date: **8/30/2016**

CLIENT: Linn Benton Lincoln ESD

Project: Lead Testing

This report presents the results of the analyses of the sample(s) received on the date above and assigned the listed ALG lab report numbers. Test results relate only to the parameters tested and to the samples as received by the laboratory.

This report shall not be reproduced, except in full, without written consent of Analytical Laboratory Group, Inc.

All analyses were performed according to the Analytical Laboratory Group, Inc. Quality Assurance Program.

All QA/QC requirements were met except as noted below.

Analytical comments are noted with data flags on the reports and/or below.

Original

Page 2 of 10



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Analytical Report

Date Reported 8/30/2016

WO#: 1608431
CLIENT: Linn Benton Lincoln ESD
Project: Lead Testing
PWS Number:
Sample Source:

Received Date: 8/9/2016 2:45:00 PM
Sampler Name Rich Swanson
Matrix: Drinking Water
Sample Type:

| Lab ID: 1608431-001 | Client Sample ID 3rd Floor Restroom Sink - 1 | Collection Date: 8/9/2016 5:26:00 AM | | | | | | |
|----------------------------|---|---|--------|---------|------|-------|----------------------|--------|
| Analyses | Method | Result | MCL | RL | Qual | Units | Date Analyzed | Analys |
| Lead | SM 3113 B | ND | 0.0200 | 0.00200 | | mg/L | 8/28/2016 4:51:00 PM | KG |

| | | | | | | | | |
|---------------------|------------------|------------------------------|--------|---------|--------------------------------------|-------|----------------------|--------|
| Lab ID: 1608431-002 | Client Sample ID | 3rd Floor Water Fountain - 2 | | | Collection Date: 8/9/2016 5:29:00 AM | | | |
| Analyses | Method | Result | MCL | RL | Qual | Units | Date Analyzed | Analys |
| Lead | SM 3113 B | ND | 0.0200 | 0.00200 | | mg/L | 8/28/2016 4:51:00 PM | KG |

| Lab ID: 1608431-003 | Client Sample ID 2nd Floor Restroom Stair Well - 3 | Collection Date: 8/9/2016 5:34:00 AM | | | | | | |
|----------------------------|---|---|--------|---------|------|-------|----------------------|--------|
| Analyses | Method | Result | MCL | RL | Qual | Units | Date Analyzed | Analys |
| Lead | SM 3113 B | ND | 0.0200 | 0.00200 | | mg/L | 8/29/2016 8:00:00 PM | PG |

| | | | | | | | | |
|---------------------|------------------|---------------------------|--------|---------|------|--------------------------------------|----------------------|--------|
| Lab ID: 1608431-004 | Client Sample ID | 2nd Floor Restroom HR - 4 | | | | Collection Date: 8/9/2016 5:37:00 AM | | |
| Analyses | Method | Result | MCL | RL | Qual | Units | Date Analyzed | Analys |
| Lead | SM 3113 B | 0.00217 | 0.0200 | 0.00200 | | mg/L | 8/29/2016 8:00:00 PM | PG |

| | | | | | | | | |
|----------------------------|-------------------------|----------------------------------|------------|-----------|---|--------------|----------------------|---------------|
| Lab ID: 1608431-005 | Client Sample ID | 2nd Floor Water Fountain by HR - | | | Collection Date: 8/9/2016 5:39:00 AM | | | |
| Analyses | Method | Result | MCL | RL | Qual | Units | Date Analyzed | Analys |
| Lead | SM 3113 B | ND | 0.0200 | 0.00200 | | mg/L | 8/29/2016 8:00:00 PM | PG |

| | | | | | | | | |
|----------------------------|--|---|------------|-----------|-------------|--------------|----------------------|---------------|
| Lab ID: 1608431-006 | Client Sample ID 2nd Floor Kitchen Faucet - 6 | Collection Date: 8/9/2016 5:42:00 AM | | | | | | |
| Analyses | Method | Result | MCL | RL | Qual | Units | Date Analyzed | Analys |
| Lead | SM 3113 B | ND | 0.0200 | 0.00200 | | mg/L | 8/29/2016 8:00:00 PM | PG |

| | | | | | | | | |
|----------------------------|-------------------------|---------------------------------|------------|-----------|---|--------------|----------------------|---------------|
| Lab ID: 1608431-007 | Client Sample ID | 2nd Floor Kitchen Water Tap - 7 | | | Collection Date: 8/9/2016 5:43:00 AM | | | |
| Analyses | Method | Result | MCL | RL | Qual | Units | Date Analyzed | Analys |
| Lead | SM 3113 B | ND | 0.0200 | 0.00200 | | mg/L | 8/29/2016 8:00:00 PM | PG |

| | | | | | | | | |
|----------------------------|-------------------------|------------------------------|------------|-----------|---|--------------|----------------------|---------------|
| Lab ID: 1608431-008 | Client Sample ID | 1st Floor Water Fountain - 8 | | | Collection Date: 8/9/2016 5:47:00 AM | | | |
| Analyses | Method | Result | MCL | RL | Qual | Units | Date Analyzed | Analys |
| Lead | SM 3113 B | ND | 0.0200 | 0.00200 | | mg/L | 8/29/2016 8:00:00 PM | PG |

| | | |
|--------------------|--|----------------------------------|
| Qualifiers: | * Value exceeds Maximum Contaminant Level (MCL) | A Accredited by ORELAP |
| | C Value is below Minimum Compound Limit. | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | LOD Limit of Detection |
| | MCL Maximum Contaminant Level | NAR See note in Case Narrative |
| | ND Not Detected at the Reporting Limit | PL Permit Limit |

WO#: 1608431
CLIENT: Linn Benton Lincoln ESD
Project: Lead Testing
PWS Number:
Sample Source:

Received Date: 8/9/2016 2:45:00 PM
Sampler Name Rich Swanson
Matrix: Drinking Water
Sample Type:

Lab ID: 1608431-009 **Client Sample ID** 1st Main Floor Sink Custodial Clos **Collection Date:** 8/9/2016 5:51:00 AM

| Analyses | Method | Result | MCL | RL | Qual | Units | Date Analyzed | Analys |
|----------|-----------|---------|--------|---------|------|-------|----------------------|--------|
| Lead | SM 3113 B | 0.00605 | 0.0200 | 0.00200 | | mg/L | 8/29/2016 8:00:00 PM | PG |

Lab ID: 1608431-010 **Client Sample ID** 1st Floor Water Fountain by CR1 - **Collection Date:** 8/9/2016 5:55:00 AM

| Analyses | Method | Result | MCL | RL | Qual | Units | Date Analyzed | Analys |
|----------|-----------|--------|--------|---------|------|-------|----------------------|--------|
| Lead | SM 3113 B | ND | 0.0200 | 0.00200 | | mg/L | 8/29/2016 8:00:00 PM | PG |

Lab ID: 1608431-011 **Client Sample ID** 1st Floor Water Fountain by CR1 - **Collection Date:** 8/9/2016 5:56:00 AM

| Analyses | Method | Result | MCL | RL | Qual | Units | Date Analyzed | Analys |
|----------|-----------|--------|--------|---------|------|-------|----------------------|--------|
| Lead | SM 3113 B | ND | 0.0200 | 0.00200 | | mg/L | 8/29/2016 8:00:00 PM | PG |

Lab ID: 1608431-012 **Client Sample ID** 1st Floor Mens RR Sinks - 11A **Collection Date:** 8/9/2016 6:00:00 AM

| Analyses | Method | Result | MCL | RL | Qual | Units | Date Analyzed | Analys |
|----------|-----------|---------|--------|---------|------|-------|----------------------|--------|
| Lead | SM 3113 B | 0.00208 | 0.0200 | 0.00200 | | mg/L | 8/29/2016 8:00:00 PM | PG |

Lab ID: 1608431-013 **Client Sample ID** 1st Floor Mens RR Sinks - 11B **Collection Date:** 8/9/2016 6:00:00 AM

| Analyses | Method | Result | MCL | RL | Qual | Units | Date Analyzed | Analys |
|----------|-----------|---------|--------|---------|------|-------|----------------------|--------|
| Lead | SM 3113 B | 0.00495 | 0.0200 | 0.00200 | | mg/L | 8/29/2016 8:00:00 PM | PG |

Lab ID: 1608431-014 **Client Sample ID** 1st Floor Mens RR Sinks - 11C **Collection Date:** 8/9/2016 6:01:00 AM

| Analyses | Method | Result | MCL | RL | Qual | Units | Date Analyzed | Analys |
|----------|-----------|--------|--------|---------|------|-------|----------------------|--------|
| Lead | SM 3113 B | ND | 0.0200 | 0.00200 | | mg/L | 8/29/2016 8:00:00 PM | PG |

Lab ID: 1608431-015 **Client Sample ID** 1st Floor Mens RR Sinks - 11D **Collection Date:** 8/9/2016 6:01:00 AM

| Analyses | Method | Result | MCL | RL | Qual | Units | Date Analyzed | Analys |
|----------|-----------|--------|--------|---------|------|-------|----------------------|--------|
| Lead | SM 3113 B | ND | 0.0200 | 0.00200 | | mg/L | 8/29/2016 8:00:00 PM | PG |

WO#: 1608431
CLIENT: Linn Benton Lincoln ESD
Project: Lead Testing
PWS Number:
Sample Source:

Received Date: 8/9/2016 2:45:00 PM
Sampler Name Rich Swanson
Matrix: Drinking Water
Sample Type:

| | | | | | | | | |
|---------------------|------------------|---------------------------------|--------|---------|------|--------------------------------------|----------------------|--------|
| Lab ID: 1608431-016 | Client Sample ID | 1st Floor Womens RR Sinks - 11E | | | | Collection Date: 8/9/2016 6:06:00 AM | | |
| Analyses | Method | Result | MCL | RL | Qual | Units | Date Analyzed | Analys |
| Lead | SM 3113 B | ND | 0.0200 | 0.00200 | | mg/L | 8/29/2016 8:00:00 PM | PG |

| | | | | | | | | |
|---------------------|------------------|---------------------------------|--------|---------|------|--------------------------------------|----------------------|--------|
| Lab ID: 1608431-017 | Client Sample ID | 1st Floor Womens RR Sinks - 11F | | | | Collection Date: 8/9/2016 6:06:00 AM | | |
| Analyses | Method | Result | MCL | RL | Qual | Units | Date Analyzed | Analys |
| Lead | SM 3113 B | 0.00204 | 0.0200 | 0.00200 | | mg/L | 8/29/2016 8:00:00 PM | PG |

| Lab ID: 1608431-018 | Client Sample ID | 1st Floor Womens RR Sinks - 11G | | | | Collection Date: 8/9/2016 6:07:00 AM | | |
|----------------------------|-------------------------|---------------------------------|--------|---------|------|---|----------------------|--------|
| Analyses | Method | Result | MCL | RL | Qual | Units | Date Analyzed | Analys |
| Lead | SM 3113 B | 0.0101 | 0.0200 | 0.00200 | | mg/L | 8/29/2016 8:00:00 PM | PG |

| | | | | | | | | |
|---------------------|------------------|---------------------------------|--------|---------|------|--------------------------------------|----------------------|--------|
| Lab ID: 1608431-019 | Client Sample ID | 1st Floor Womens RR Sinks - 11H | | | | Collection Date: 8/9/2016 6:07:00 AM | | |
| Analyses | Method | Result | MCL | RL | Qual | Units | Date Analyzed | Analys |
| Lead | SM 3113 B | 0.0173 | 0.0200 | 0.00200 | | mg/L | 8/29/2016 8:00:00 PM | PG |

| | | | | | | | | |
|---------------------|------------------|----------------------------------|--------|---------|--------------------------------------|-------|----------------------|--------|
| Lab ID: 1608431-020 | Client Sample ID | Main Floor Conf. Rm Kitchen - 12 | | | Collection Date: 8/9/2016 6:10:00 AM | | | |
| Analyses | Method | Result | MCL | RL | Qual | Units | Date Analyzed | Analys |
| Lead | SM 3113 B | 0.00375 | 0.0200 | 0.00200 | | mg/L | 8/29/2016 8:00:00 PM | PG |

| | | | | | | | | |
|----------------------------|-------------------------|-------------------------------------|------------|-----------|-------------|---|----------------------|---------------|
| Lab ID: 1608431-021 | Client Sample ID | 1st/Main Floor DF Lori's Office - 1 | | | | Collection Date: 8/9/2016 6:15:00 AM | | |
| Analyses | Method | Result | MCL | RL | Qual | Units | Date Analyzed | Analys |
| Lead | SM 3113 B | ND | 0.0200 | 0.00200 | | mg/L | 8/29/2016 8:00:00 PM | PG |

| | | | | | | | | |
|----------------------------|-------------------------|-------------------------|------------|-----------|-------------|---|----------------------|---------------|
| Lab ID: 1608431-022 | Client Sample ID | Basement Restroom - 14A | | | | Collection Date: 8/9/2016 6:22:00 AM | | |
| Analyses | Method | Result | MCL | RL | Qual | Units | Date Analyzed | Analys |
| Lead | SM 3113 B | ND | 0.0200 | 0.00200 | | mg/L | 8/29/2016 8:00:00 PM | PG |

| | | | | | | | | |
|----------------------------|-------------------------|-------------------------|------------|-----------|-------------|---|----------------------|---------------|
| Lab ID: 1608431-023 | Client Sample ID | Basement Restroom - 14B | | | | Collection Date: 8/9/2016 6:22:00 AM | | |
| Analyses | Method | Result | MCL | RL | Qual | Units | Date Analyzed | Analys |
| Lead | SM 3113 B | 0.00242 | 0.0200 | 0.00200 | | mg/L | 8/29/2016 8:00:00 PM | PG |

| | | |
|--------------------|--|----------------------------------|
| Qualifiers: | * Value exceeds Maximum Contaminant Level (MCL) | A Accredited by ORELAP |
| | C Value is below Minimum Compound Limit. | E Value above quantitation range |
| | H Holding times for preparation or analysis exceeded | LOD Limit of Detection |
| | MCL Maximum Contaminant Level | NAR See note in Case Narrative |
| | ND Not Detected at the Reporting Limit | PL Permit Limit |



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Analytical Report

Date Reported 8/30/2016

WO#: 1608431
CLIENT: Linn Benton Lincoln ESD
Project: Lead Testing
PWS Number:
Sample Source:

Received Date: 8/9/2016 2:45:00 PM
Sampler Name Rich Swanson
Matrix: Drinking Water
Sample Type:

Lab ID: 1608431-024 **Client Sample ID** Basement Sink Custodial Supply - 1 **Collection Date:** 8/9/2016 6:25:00 AM

| Analyses | Method | Result | MCL | RL | Qual | Units | Date Analyzed | Analys |
|----------|-----------|--------|--------|---------|------|-------|----------------------|--------|
| Lead | SM 3113 B | 0.0219 | 0.0200 | 0.00400 | * | mg/L | 8/29/2016 8:00:00 PM | PG |

Lab ID: 1608431-025 **Client Sample ID** Basement Sink Rm #15 - 16 **Collection Date:** 8/9/2016 6:27:00 AM

| Analyses | Method | Result | MCL | RL | Qual | Units | Date Analyzed | Analys |
|----------|-----------|---------|--------|---------|------|-------|----------------------|--------|
| Lead | SM 3113 B | 0.00466 | 0.0200 | 0.00200 | | mg/L | 8/29/2016 8:00:00 PM | PG |

Lab ID: 1608431-026 **Client Sample ID** Basement E1 Sink Classroom - 17 **Collection Date:** 8/9/2016 6:34:00 AM

| Analyses | Method | Result | MCL | RL | Qual | Units | Date Analyzed | Analys |
|----------|-----------|---------|--------|---------|------|-------|----------------------|--------|
| Lead | SM 3113 B | 0.00565 | 0.0200 | 0.00200 | | mg/L | 8/29/2016 8:00:00 PM | PG |

Lab ID: 1608431-027 **Client Sample ID** Basement E1 Sink Bathroom - 18 **Collection Date:** 8/9/2016 6:35:00 AM

| Analyses | Method | Result | MCL | RL | Qual | Units | Date Analyzed | Analys |
|----------|-----------|--------|--------|---------|------|-------|----------------------|--------|
| Lead | SM 3113 B | ND | 0.0200 | 0.00200 | | mg/L | 8/29/2016 8:00:00 PM | PG |

Lab ID: 1608431-028 **Client Sample ID** Basement E1 Water Fountain - 19A **Collection Date:** 8/9/2016 6:36:00 AM

| Analyses | Method | Result | MCL | RL | Qual | Units | Date Analyzed | Analys |
|----------|-----------|---------|--------|---------|------|-------|----------------------|--------|
| Lead | SM 3113 B | 0.00308 | 0.0200 | 0.00200 | | mg/L | 8/29/2016 8:00:00 PM | PG |

Lab ID: 1608431-029 **Client Sample ID** Basement E1 Water Fountain - 19B **Collection Date:** 8/9/2016 6:36:00 AM

| Analyses | Method | Result | MCL | RL | Qual | Units | Date Analyzed | Analys |
|----------|-----------|---------|--------|---------|------|-------|----------------------|--------|
| Lead | SM 3113 B | 0.00412 | 0.0200 | 0.00200 | | mg/L | 8/29/2016 8:00:00 PM | PG |

Qualifiers:

- * Value exceeds Maximum Contaminant Level (MCL)
- C Value is below Minimum Compound Limit.
- H Holding times for preparation or analysis exceeded
- MCL Maximum Contaminant Level
- ND Not Detected at the Reporting Limit

- A Accredited by ORELAP
- E Value above quantitation range
- LOD Limit of Detection
- NAR See note in Case Narrative
- PL Permit Limit

Original
Page 6 of 10



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Accreditation Program Analytes Report

WO#: 1608431

30-Aug-16

Client: Linn Benton Lincoln ESD

Project: Lead Testing

| Program Name | Sample ID | ClientSampleID | Matrix | Test Name | Analyte | Status |
|--------------|--------------|--|----------------|------------------------------------|---------|--------|
| ORELAP | 1608431-001A | 3rd Floor Restroom Sink - 1 | Drinking Water | AA Metals by SM 3113 Schools 250mL | Lead | A |
| | 1608431-002A | 3rd Floor Water Fountain - 2 | | | Lead | A |
| | 1608431-003A | 2nd Floor Restroom Stair Well - 3 | | | Lead | A |
| | 1608431-004A | 2nd Floor Restroom HR - 4 | | | Lead | A |
| | 1608431-005A | 2nd Floor Water Fountain by HR - 5 | | | Lead | A |
| | 1608431-006A | 2nd Floor Kitchen Faucet - 6 | | | Lead | A |
| | 1608431-007A | 2nd Floor Kitchen Water Tap - 7 | | | Lead | A |
| | 1608431-008A | 1st Floor Water Fountain - 8 | | | Lead | A |
| | 1608431-009A | 1st Main Floor Sink Custodial Closet - 9 | | | Lead | A |
| | 1608431-010A | 1st Floor Water Fountain by CR1 - 10A | | | Lead | A |
| | 1608431-011A | 1st Floor Water Fountain by CR1 - 10B | | | Lead | A |
| | 1608431-012A | 1st Floor Mens RR Sinks - 11A | | | Lead | A |
| | 1608431-013A | 1st Floor Mens RR Sinks - 11B | | | Lead | A |
| | 1608431-014A | 1st Floor Mens RR Sinks - 11C | | | Lead | A |
| | 1608431-015A | 1st Floor Mens RR Sinks - 11D | | | Lead | A |
| | 1608431-016A | 1st Floor Womens RR Sinks - 11E | | | Lead | A |
| | 1608431-017A | 1st Floor Womens RR Sinks - 11F | | | Lead | A |
| | 1608431-018A | 1st Floor Womens RR Sinks - 11G | | | Lead | A |
| | 1608431-019A | 1st Floor Womens RR Sinks - 11H | | | Lead | A |
| | 1608431-020A | Main Floor Conf. Rm Kitchen - 12 | | | Lead | A |

ACCRED
ORELAP A Accredited

Original #1608431# v1

Page 7 of 10



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Accreditation Program Analytes Report

WO#: 1608431

30-Aug-16

Client: Linn Benton Lincoln ESD

Project: Lead Testing

| Program Name | Sample ID | ClientSampleID | Matrix | Test Name | Analyte | Status |
|--------------|--------------|---|----------------|---------------------------------------|---------|--------|
| ORELAP | 1608431-021A | 1st/Main Floor DF Lori's Office - 13 | Drinking Water | AA Metals by SM 3113 Schools 250mL | Lead | A |
| | 1608431-022A | Basement Restroom - 14A | | | Lead | A |
| | 1608431-023A | Basement Restroom - 14B | | | Lead | A |
| | 1608431-024A | Basement Sink Custodial Supply - 15 | | | Lead | A |
| | 1608431-025A | Basement Sink Rm #15 - 16 | | | Lead | A |
| | 1608431-026A | Basement E1 Sink Classroom - 17 | | | Lead | A |
| | 1608431-027A | Basement E1 Sink Bathroom - 18 | | | Lead | A |
| | 1608431-028A | Basement E1 Water Fountain - 19A | | | Lead | A |
| | 1608431-029A | Basement E1 Water Fountain - 19B | | | Lead | A |

ACCRED
ORELAP A Accredited

Original #1608431# v1

Page 8 of 10



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Definition Base

WO#: 1608431

Date: 8/30/2016

Definitions:

% REC: Percent Recovery; a measure of accuracy expressed as a percentage of a measured (recovered) concentration compared to the known concentration added to the sample.

% RPD: Relative Percent Difference; a measure of precision expressed as a percentage of the difference between two duplicates relative to the average concentration.

DF: Dilution factor; the dilution factor applied to the prepared sample.

DUP: Duplicate; aliquots of a sample taken from the same container under laboratory conditions and processed and analyzed independently, used to calculate Precision (%RPD).

LCS: Laboratory Control Sample; prepared by adding a known mass of target analytes to a specified amount of de-ionized water and prepared with the batch of samples, used to calculate Accuracy (%REC).

LCSD: The duplicate sample of the LCS, used to calculate both Accuracy (%REC) and Precision (%RPD)

MBLK: Method Blank; a sample of similar matrix that is processed simultaneously with and under the same conditions as samples through all steps of the analytical procedure, and in which no target analytes or interferences are present at concentrations that impact the analytical results for sample analyses.

MS: Matrix Spike; prepared by adding a known mass of target analytes to a specified amount of matrix sample for which an independent estimate of target analyte concentration is available, used to calculate Accuracy (%REC)

MSD: The duplicate sample of the MS, used to calculate both Accuracy (%REC) and Precision (%RPD)

ND: Not Detected. The analyte level is below the lowest point the laboratory can test for.

PL: Permit limit; only applicable to wastewater reports.

PQL: Practical Quantitation Level or Reporting Limit; the limit to which data is compared for reporting.

Qual: Qualifier that applies to the analyte reported



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Definition Base

WO#: 1608431

Date: 8/30/2016

Definitions:

Result: Analyte concentration reported

RL: Reporting Limit/Limit of Quantitation; the limit to which data is compared for reporting. Analyte concentrations below the reporting limit are reported as ND or with a “J” qualifier.

Units: The units in which the analyte concentration is reported.

Qualifiers:

| | |
|-----|---|
| * | Value exceeds Maximum Contaminant Level (MCL) |
| A | Accredited by ORELAP |
| C | Value is below Minimum Compound Limit. |
| E | Value above quantitation range |
| H | Holding times for preparation or analysis exceeded |
| LOD | Limit of Detection |
| MCL | Maximum Contaminant Level |
| NAR | See note in Case Narrative |
| ND | Not Detected at the Reporting Limit |
| PL | Permit Limit |
| R | RPD outside accepted recovery limits |
| RL | Reporting Detection Limit |
| U | Samples with CalcVal < MDL |
| W | Sample container temperature is out of limit as specified at testcode |

Analytical Laboratory Group, Inc.

361 WEST FIFTH AVENUE

EUGENE, OREGON 97401

800-262-5973/541-485-8404 Fax 541-484-5995

Email: alglabs@alglabsinc.comDeliv
just

PUC

CHAIN OF CUSTODY

Attention: Bonny Ray

Client: Linn Benton Lincoln ESD

Phone: 541-812-2712

Address: 905 4th Avenue SE

Email: bonny.ray@lblead.k12.or.us

City, State, Zip Albany, OR 97321

Client Project:

Lead Testing

Sampler: Print

Rich Swanson

Sampler: Signature

Rich Swanson

| Client ID | Sample Matrix & Grab/Comp | Collection | | Analysis Requested | Bottles - Lab Use Only | | | | |
|----------------------------------|---------------------------|------------|------|--------------------|------------------------|---|------|------|--------|
| | | Date | Time | | Type | # | Pres | T °C | Lab ID |
| 3rd floor restrooms sink | 1 | 8-9-16 | 5:26 | Lead | P | 1 | | | 001A |
| 3rd floor water fountain | 2 | 8-9-16 | 5:29 | Lead | P | 1 | | | 002A |
| 2nd floor restroom stair well | 3 | 8-9-16 | 5:34 | Lead | P | 1 | | | 003A |
| 2nd floor restroom HR | 4 | 8-9-16 | 5:37 | Lead | P | 1 | | | 004A |
| 2nd floor water fountain (by HR) | 5 | 8-9-16 | 5:39 | Lead | P | 1 | | | 005A |
| 2nd floor Kitchen faucet | 6 | 8-9-16 | 5:42 | Lead | P | 1 | | | 006A |
| 2nd floor Kitchen water tap | 7 | 8-9-16 | 5:43 | Lead | P | 1 | | | 007A |
| 1st floor water fountain | 8 | 8-9-16 | 5:47 | Lead | P | 1 | | | 008A |
| (1st) Main floor sink closet | 9 | 8-9-16 | 5:51 | Lead | P | 1 | | | 009A |
| 1st floor water fountain by CRI | 10A | 8-9-16 | 5:55 | Lead | P | 1 | | | 010A |

Notes:

Preservation Check

| Lab ID | Date/Time | Pre-Preserved | pH | Tech |
|--------|-----------|---------------|----|------|
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |

Turn Around Time Requested (Rush incurs a Surcharge):

☒ NORMAL☐ RUSH

Shipped Via:

ALG Courier

Refrigerated

N/A

Relinquished by:

Rich Swanson

Date Time

8/9 12:15

Received by:

Bonny Ray

Date Time

8/9 12:15

Relinquished by:

Bonny Ray

Date Time

8/9 1:00

Received by:

[Signature]

Date Time

8/9/16 1300

Relinquished by:

Date Time

8/9/16 1445

Received by Laboratory:

Cynthia Kelly

Date Time

8/9/16 14:45

Analytical Laboratory Group, Inc.

361 WEST FIFTH AVENUE

EUGENE, OREGON 97401

800-262-5973/541-485-8404 Fax 541-484-5995

Email: alglabs@alglabsinc.comDeliver!
just for:

NPUC

CHAIN OF CUSTODY

Attention: Bonny Ray

Client: Linn Benton Lincoln ESD

Phone: 541-812-2712

Address: 905 4th Avenue SE

Email: bonny.ray@lblead.k12.or.us

City, State, Zip Albany, OR 97321

Client Project: Lead Testing

Sampler: Print
RICH SWANSON

Sampler: Signature

Rich Swanson

| Client ID | Sample Matrix & Grab/Comp | Collection | | Analysis Requested | Bottles - Lab Use Only | | | | |
|-----------------------------------|---------------------------|------------|------|--------------------|------------------------|---|------|------|--------|
| | | Date | Time | | Type | # | Pres | T °C | Lab ID |
| 1st floor water fountain by CRI | 10B | 8-9-16 | 5:56 | Lead | P | 1 | | | 011A |
| 1st floor restrooms sinks Men's | 11A | 8-9-16 | 6:00 | Lead | P | 1 | | | 012A |
| " " " | 11B | 8-9-16 | 6:00 | Lead | P | 1 | | | 013A |
| " " " | 11C | 8-9-16 | 6:01 | Lead | P | 1 | | | 014A |
| " " " | 11D | 8-9-16 | 6:01 | Lead | P | 1 | | | 015A |
| 1st floor restrooms sinks Women's | 11E | 8-9-16 | 6:06 | Lead | P | 1 | | | 016A |
| " " " | 11F | 8-9-16 | 6:06 | Lead | P | 1 | | | 017A |
| " " " | 11G | 8-9-16 | 6:07 | Lead | P | 1 | | | 018A |
| " " " | 11H | 8-9-16 | 6:07 | Lead | P | 1 | | | 019A |
| Main Floor Conf. Rm Kitchen | 12 | 8-9-16 | 6:10 | Lead | P | 1 | | | 020A |

Notes:

Preservation Check

| Lab ID | Date/Time | Pre-Preserved | pH | Tech |
|--------|-----------|---------------|----|------|
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |

Turn Around Time Requested (Rush incurs a Surcharge):

☒ NORMAL ☐ RUSH

Shipped Via:

ALG Courier

Refrigerated

N/A

Relinquished by:

Rich Swanson

Date Time

8/9 12:15

Received by:

Bonny Ray

Date Time

8/9 12:15

Relinquished by:

Bonny Ray

Date Time

8/9 1:00

Received by:

[Signature]

Date Time

8/9/16 1300

Relinquished by:

[Signature]

Date Time

8/9/16 1445

Received by Laboratory:

Cynthia O'Kelly

Date Time

8/9/16 14:45

Analytical Laboratory Group, Inc.

361 WEST FIFTH AVENUE
EUGENE, OREGON 97401
800-262-5973/541-485-8404 Fax 541-484-5995
Email: alglabs@alglabsinc.com



Deliver
just test

NPUC

CHAIN OF CUSTODY

| | |
|---|--|
| Attention: Bonny Ray | Client: Linn Benton Lincoln ESD |
| Phone: 541-812-2712 | Address: 905 4th Avenue SE |
| Email: bonny.ray@lblead.k12.or.us | City, State, Zip: Albany, OR 97321 |
| Client Project: Lead Testing | Sampler: Print Rich Swanson Sampler: Signature <i>Rich Swanson</i> |

| Client ID | Sample Matrix & Grab/Comp | Collection | | Analysis Requested | Bottles - Lab Use Only | | | | |
|-----------------------------------|---------------------------|------------|------|--------------------|------------------------|---|------|------|--------|
| | | Date | Time | | Type | # | Pres | T °C | Lab ID |
| 1st/ Main floor drinking fountain | 13 | 8-9-16 | 6:15 | Lead | P | 1 | | | 021A |
| Basement Restroom | 14A | 8-9-16 | 6:22 | Lead | P | 1 | | | 022A |
| Basement restroom | 14B | 8-9-16 | 6:22 | Lead | P | 1 | | | 023A |
| Basement sink Custodial Supply | 15 | 8-9-16 | 6:25 | Lead | P | 1 | | | 024A |
| Basement sink Rm# 15 | 16 | 8-9-16 | 6:27 | Lead | P | 1 | | | 025A |
| Basement El sink (Classroom) | 17 | 8-9-16 | 6:34 | Lead | P | 1 | | | 026A |
| Basement El sink (Bathroom) | 18 | 8-9-16 | 6:35 | Lead | P | 1 | | | 027A |
| Basement El water fountain | 19A | 8-9-16 | 6:36 | Lead | P | 1 | | | 028A |
| Basement El water fountain | 19B | 8-9-16 | 6:36 | Lead | P | 1 | | | 029A |
| | | | | Lead | P | 1 | | | 030A |

| | | | | | |
|--------|----------------------------------|-----------|---------------|----|------|
| Notes: | Preservation Check <u>8/9/16</u> | | | | |
| | Lab ID | Date/Time | Pre-Preserved | pH | Tech |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |

| | | |
|---|--|--|
| Turn Around Time Requested (Rush incurs a Surcharge): <input checked="" type="checkbox"/> NORMAL <input type="checkbox"/> RUSH | Shipped Via: ALG Courier | Refrigerated: N/A |
| Relinquished by: <i>Rich Swanson</i> | Date: 8/9 Time: 12:15 | Received by: <i>Bonny Ray</i> |
| Relinquished by: <i>Bonny Ray</i> | Date: 8/9 Time: 1:00 | Received by: <i>[Signature]</i> |
| Relinquished by: <i>[Signature]</i> | Date: 8/9/16 Time: 14:45 | Received by Laboratory: <i>Arthur Okella</i> |
| | | Date: 8/9/16 Time: 14:45 |

NOTE: MAIN FLOOR = 2
1ST FLOOR

Water Test Locations at LBL Main Building (30 total possibly)

Multiple sample areas will be numbered and lettered A to Z from left to right positions

1. 3rd Floor restroom sink ✓
2. 3rd Floor water fountain ✓
3. 2nd Floor restroom in stair well ✓
4. 2nd Floor restroom at landing near HR ✓
5. 2nd Floor water fountain by HR ✓
6. 2nd Floor Kitchen faucet ✓
7. 2nd Floor Kitchen filtered water tap ✓
8. Main Floor water fountain by Jackie's office ✓
9. Main Floor sink in custodial closet by Network office ✓
10. Main Floor **two** water fountains by CR1 ✓
 - 10a. ✓
 - 10b. ✓
11. Main Floor **eight** faucets in Conference room restrooms —
 - 11a. ✓
 - 11b. ✓
 - 11c. ✓ MENS
 - 11d. ✓
 - 11e. ✓
 - 11f. ✓
 - 11g. ✓ WOMENS
 - 11h. ✓
12. Main Floor Conference room kitchen sink ✓
13. Main Floor Drinking Fountain by Network/Lori's office ✓
14. Basement **two** restroom faucets —
 - 14a. ✓
 - 14b. ✓
15. Basement sink in custodial supply room ✓
16. Basement sink in equipment storage room 15 (Diva Den office) ✓
17. Basement Early Intervention Classroom sink ✓
18. Basement Early Intervention Bathroom sink ✓
19. Basement **two** water fountains in Early Intervention room (~~or disabled/removed~~)
 - 19a. ✓
 - 19b. ✓
- ~~20.~~ Basement shower (or capped off)